



NATIONAL REFINERY LIMITED

7-B, Korangi Industrial Zone, Korangi, Karachi-74900, (Pakistan)
P.O.Box No. 8228
Telephone: 35064981-3 PABX Fax: 92-21-35054663 Direct:35121836
smgr_procurement@nrlpak.com

Request For Quotation

Page 1 of 3.

Our Ref No. WHF-3881

No. 6100021432
Dated 06.11.2023

Due Date: 19.12.2023

Shipment to Karachi Via: Air / Sea

Shipment to Karachi By : _____

Manager Imports

Please send us your best offer in the form of Performa Invoice on your letterhead based on C&F Karachi and at least provide the gross weight & dimensions along with complete address of Ex-works/ FOB destination, duly signed, for the under mentioned items. In case of local agents / representative original Invoice from the Principal must be enclosed. Quotation should be submitted along with our attached "BID FORM" completely filled in.

Incomplete and conditional offers will not be entertained. No advance payment will be made. All bank charges inside Pakistan will be on our account and all bank charges outside Pakistan will be on beneficiary's account. The bids are to be submitted in the sealed envelope clearly marked as Manager Imports and our reference No. mentioned above and courier/ e-mail to us. Please e-mail/ fax us your courier Slip No. The bids to be reached latest by the above mentioned date.

Item	Material	Description	Unit	Quantity	Unit Price	Freight/ Packing Charges	Total C&F Value (Currency)
00010	51-226-832K1	CCU : 1TNB302401R0105 (8E/2) : 63A REAR CABLE CONNECTION UNIT(CCU) 1TNB302401R0105 FOR 63A REAR MOUNTING	NO	2			
00020	51-226-205K1	CONTROL TERMINAL CONNECTOR: CNILX JHD-78 PART NUMBER: CNILX JHD-78 1TNA100118R PA66 HDD 500V, 10A, 1MM2 MAKE: ABB	NO	10			
00030	51-226-206K1	CONTROL TERMINAL BASE : CNILX D-7B PART NUMBER: CNILX D-7B 1TNA100118R PA66 HDD 500V, 10A, 1MM2 MAKE: ABB	NO	5			
00040	51-226-207K1	CONTROL TERMINAL CONNECTOR : JHD-7A2 PART NUMBER: JHD-7A2 1TNA100115R PA66 HDD 500V, 10A, 2.5MM2 MAKE: ABB	NO	10			

YOUR REF. NO.

DATE:

AUTHORIZED SIGNATURE



NATIONAL REFINERY LIMITED

7-B, Korangi Industrial Zone, Korangi, Karachi-74900, (Pakistan)
P.O.Box No. 8228
Telephone: 35064981-3 PABX Fax: 92-21-35054663 Direct: 35121836
smgr_procurement@nrlpak.com

Request For Quotation

Page 2 of 3.

Tel :
Fax :
Vendor No. 200861

Our Ref No. WHF-3881

No. 6100021432
Dated 06.11.2023

Due Date: 19.12.2023

Shipment to Karachi Via: Air / Sea

Shipment to Karachi By : _____

Item	Material	Description	Unit	Quantity	Unit Price	Freight/ Packing Charges	Total C&F Value (Currency)
00050	51-226-208K1	CONTROL TERMINAL BASE : CNILX D-7AF PART NUMBER: CNILX D-7AF 1TNA100115R PA66 HDD 500V, 10A, 2.5MM2 MAKE: ABB	NO	5			
00060	51-226-209K1	CONTROL TERMINAL MALE CONNECTOR : HP-52E PART NUMBER: HP-52E GILN100118R PA66 HDD 500V, 10A, 1.5MM2 MAKE: ABB	NO	10			
00070	51-226-857K1	OPERATING MECHANISM : SIDE MOUNTED FOR 8E/2 WITHDRAWAL MODULE	NO	3			
00080	51-226-210K1	CONTROL TERMINAL : 8E/2 BREAKERS FOR USE WITH ABB MNS BREAKERS IN 8E/2 MODULES NO. OF POLES : 24	NO	8			
00090	14-302-031K1	MOTOR AUTO RESTART RELAY CONTROL VOLTAGE 220VAC ON CONTACT 8A 440VAC RUN SIGNAL 5A 250VAC/30VDC ALLOWABLE NO VOLTAGE TIME LIMIT 2.0s MAKE: SHENZHEN BEITON TECHNOLOGY OR ANY SUITABLE ALTERNATE PUPOSE: DZQ (MOTOR REACCELERATION RELAY)	NO	5			
00100	51-226-574K1	CONTROL TRANSFORMER : RN1-4000-1 AC400/AC230 POWER : 4KVA FREQUENCY : 50Hz INSULATION CLASS : E	NO	2			



NATIONAL REFINERY LIMITED

7-B, Korangi Industrial Zone, Korangi, Karachi-74900, (Pakistan)
P.O.Box No. 8228
Telephone: 35064981-3 PABX Fax: 92-21-35054663 Direct: 35121836
smgr_procurement@nrlpak.com

Request For Quotation

Page 3 of 3.

Tel :
Fax :
Vendor No. 200861

Our Ref No. WHF-3881

No. 6100021432
Dated 06.11.2023

Due Date: 19.12.2023

Shipment to Karachi Via: Air / Sea

Shipment to Karachi By : _____

Item	Material	Description	Unit	Quantity	Unit Price	Freight/ Packing Charges	Total C&F Value (Currency)
00110	51-226-579K1	CONTROL TRANSFORMER : RN1-1500-E AC400/AC230 POWER : 1.5KVA FREQUENCY : 50HZ INSULATION CLASS : E	NO	2			
00120	51-226-577K1	CONTROL TRANSFORMER : RN1-1000-K AC400/AC230 POWER : 1KVA FREQUENCY : 50HZ INSULATION CLASS : E	NO	3			
00130	51-226-576K1	CONTROL TRANSFORMER : RN1-500-S AC400/AC230 POWER : 0.5KVA FREQUENCY : 50HZ INSULATION CLASS : E	NO	2			
00140	14-019-197K1	LIGHT CONTROL SWITCH (EE171) MODEL : EE171 AC230 MAKE : HAGER WORKING WITH PHOTOCELL	NO	3			